



ROUND PATTERN CALIBRATION PROGRAM

PAGE 01 of 01
DATE 10-19-03
TIME 16:36:05

THEORETICAL CALIBRATION FOR
SERIAL NUMBER 4GK005101-04
MODEL NUMBER TKA-F2-R 3400X1
CAPACITY OF COMPARTMENT ONE

3,400 NOMINAL GALLONS + 0.00%
3,400 GALLONS SHELL FULL

- NOTES: 1. CAPACITY IN U.S GALLONS - TANK ASSUMED LEVEL.
- 2. CALIBRATION COMPUTED MATHEMATICALLY - NOT LEGAL FOR TRADE.
- 3. FLUID CAPACITY OF PIPING NOT INCLUDED.

DEPTH	.00	.25	.50	.75	DEPTH	.00	.25	.50	.75
--- U.S. GALLONS ---					--- U.S. GALLONS ---				
0 IN	0	2	7	12	1 IN	19	26	35	44
2 IN	53	64	74	86	3 IN	98	110	123	136
4 IN	149	163	178	192	5 IN	207	223	238	254
6 IN	271	287	304	321	7 IN	339	357	375	393
8 IN	411	430	449	468	9 IN	487	507	527	547
10 IN	567	587	608	628	11 IN	649	670	691	713
12 IN	734	756	778	799	13 IN	821	844	866	888
14 IN	911	934	956	979	15 IN	1002	1025	1048	1072
16 IN	1095	1118	1142	1166	17 IN	1189	1213	1237	1261
18 IN	1284	1308	1333	1357	19 IN	1381	1405	1429	1453
20 IN	1478	1502	1526	1551	21 IN	1575	1600	1624	1648
22 IN	1673	1697	1722	1746	23 IN	1771	1795	1820	1844
24 IN	1869	1893	1917	1942	25 IN	1966	1990	2015	2039
26 IN	2063	2087	2111	2135	27 IN	2159	2183	2207	2231
28 IN	2255	2278	2302	2326	29 IN	2349	2372	2396	2419
30 IN	2442	2465	2488	2511	31 IN	2533	2556	2578	2601
32 IN	2623	2645	2667	2689	33 IN	2711	2732	2753	2775
34 IN	2796	2817	2837	2858	35 IN	2878	2899	2919	2938
36 IN	2958	2977	2997	3016	37 IN	3034	3053	3071	3089
38 IN	3107	3125	3142	3159	39 IN	3176	3192	3208	3224
40 IN	3240	3255	3270	3284	41 IN	3298	3312	3325	3338
42 IN	3350	3362	3374	3385	43 IN	3395	3405	3414	3423
44 IN	3431	3438	3444	3449	45 IN	3452			